6 Conclusion

The samples of WO-34790 20 oz. fabric backed vinyl wallcovering submitted by J Josephson Inc, exhibited the following flame spread characteristics when tested in accordance CAN/ULC S102.2-10, *Standard Method of Test for Surface Burning Characteristics of Flooring, Floor Covering, and Miscellaneous Materials and Assemblies*.

A series of three test runs was conducted to conform to the requirements of the National Building Code of Canada.

Sample Material	Flame Spread Classification	Smoke Developed Classification
WO-34790 20 oz. Fabric Backed Vinyl Wallcovering	0	45

The conclusions of this test report may not be used as part of the requirements for Intertek product certification.

INTERTEK TESTING SERVICES NA LTD.

Tested and
Reported by: _____
Greg Philp
Technician – Building Products

Reviewed by: _____
Scott Leduc, EIT
Test Engineer – Building Products

GP